Room Name	Length	Width	Height	Area m3	Rounded Area	Area x 22 Watts	Heater Required
Lounge	3500	4000	2400	33.6	34	748	1 - 1200 x 600

Element Size	Approx. Power Useage
600mm x 400mm	200
650mm x 550mm	320
900mm x 600mm	480
1100mm x 600mm	580
1200mm x 600mm	750

infraNOMIC Energy Solutions Limited

If in doubt please contact our support team:	0845 521 3034 (Local Rate)
	07791 027 416

All recommended sizes to heating area using this calculation are subject to the overall insulation value of the property and have been calculated based on having modern Low Emissity Double Glazing installed.